
PVA-1EB PAVIRO Emergency button

www.boschsecurity.com





- ► Transparent cover reliable method of preventing accidental actuation
- ► Installed LED optical visualization with maximum efficiency and operational reliability
- ► Internal monitoring the feed line is monitored for short-circuits and interruptions

The PVA-1EB is an optional button for installation in the PAVIRO call stations. For more information, see the call station documentation or IRIS-Net documentation.


Certifications and approvals


EN 54-16: 2008

Installation/configuration notes

Labeling

- 1. Remove button 1 from housing 2
- 2. Remove red diffusor **3** from lens **5** using a sharp tool (such as a knife)
- 3. Label the film insert 4
- 4. Re-assemble the button including the film insert and mount into the housing 2







Assembly in call station

- 1. Disconnect the call station from all connectors
- 2. Unscrew the call station baseplate (4 screws 1)
- 3. Carefully remove the baseplate from the upper part, start on the top left corner of the call station.
- Unplug the connecting cable from the CN1 plug connector 2
- 5. Prepare installation location **3**: Use a sharp object (scriber or similar) to carefully punch through and cut out the pre-cut rectangle on the inside of the housing. Perform any follow-up work that may be required to the installation location (e.g. filing, trimming)

2 | PVA-1EB PAVIRO Emergency button

- Mount the button into the installation location, and press in evenly (it must be possible for the cover cap to open upward)
- Depending on whether the right/middle/left installation location is used, plug the ribbon cable 4 into plug connector CN201/CN202/CN203 on the circuit board
- 8. Plug the connecting cable into CN1 again
- 9. Carefully re-attach the call station baseplate
- 10. Re-connect the connections
- 11. Configure the button using the software





Parts included

Quantity	Component
1	Button element with cover
1	Preconfigured 4-pin connecting cable
1	Installation note

Ordering information

PVA-1EB PAVIRO Emergency button

Order number PVA-1EB

Represented by:

Americas:

Americas: Bosch Security Systems, Inc. 12000 Portland Avenue South Burnsville MN 55337, USA Phone: +1-800-392-3497 Fax: +1-800-955-6831 audiosupport@us.bosch.com www.boschsecurity.com

Europe, Middle East, Africa:

Bosch Security Systems B.V. P.O. Box 80002 P.O. Box 80002 5617 BA Eindhoven, The Netherlands Phone: + 31 40 2577 284 Fax: +31 40 2577 330 emea.securitysystems@bosch.com www.boschsecurity.com

Asia-Pacific:

Asia-Pacific:
Robert Bosch (SEA) Pte Ltd, Security
Systems
11 Bishan Street 21
Singapore 573943
Phone: +65 6571 2808
Fax: +65 6571 2699
apr.securitysystems@bosch.com
www.boschsecurity.asia

China:

China:
Bosch (Shanghai) Security Systems Ltd.
201 Building, No. 333 Fuquan Road
North IBP
Changning District, Shanghai
200335 China
Phone +86 21 22181111
Fax: +86 21 22182398 www.boschsecurity.com.cn

America Latina:

America Latina:
Robert Bosch Ltda Security Systems Division
Via Anhanguera, Km 98
CEP 13065-900
Campinas, Sao Paulo, Brazil
Phone: +55 19 2103 2860
Fax: +55 19 2103 2862
latam.boschsecurity@bosch.com
www.boschsecurity.com